



TÜV NORD CERT

**Certificate about the testing of the
degrees of protection provided by enclosures**

Testing laboratory
Safety of technical systems

Client: Rolec
Gehäuse-Systeme GmbH
Kreuzbreite 2

D – 31737 Rinteln

**Devices under
test:** Enclosure series polyKom
Series PK and PKH:
PK 081 until PK 411

PKH 081 until PKH 084

**Tested in accordance
to:** EN 60529: 2000 Degrees of protection provided by
enclosures (IP Code)
Requirements towards system of
protection IP 65
Enclosures of category I;
Dust test with negative pressure

Conductor of test: A. Schmidt

Order number: 8000307813

Period of test: 10.11.2003

Result: The enclosure series polyKom fulfils the requirements of
the degrees of protection IP 65

TÜV NORD CERT GmbH & Co. KG
Am TÜV 1

D – 30519 Hannover

Hannover, 25.11.2003

K. H. Schwedt
Head of testing laboratory
Safety of technical systems