



TÜV NORD CERT

**Certificate about the testing of the
degrees of protection provided by enclosures**

78/781/551668/A

Testing laboratory
Safety of technical systems

Client: Rolec
Gehäuse-Systeme GmbH
Kreuzbreite 2

D – 31737 Rinteln

**Devices under
test:** Enclosure series mobilCase
Series:

P 80-1 DF/DK

P 100-1 DF/DK

**Tested in accordance
to:** EN 60529: 2000 Degrees of protection provided by
enclosures (IP Code)
Requirements towards system of
protection IP 65
Enclosures of category I;
Dust test with negative pressure

Conductor of test: A. Schmidt

Order number: 8000551668

Period of test: from 06.08.2004 until 02.09.2004

Result: The enclosure series mobilCase fulfils the requirements of
the degree of protection IP 65

TÜV NORD CERT GmbH & Co. KG
Am TÜV 1

D – 30519 Hannover

Hannover, 08.09.2004

K. H. Schwedt

Head of testing laboratory
Safety of technical systems